



**Princeton Department of
Emergency & Safety Services**
One Monument Drive
Princeton, NJ 08540
Tel: 609-497-7646
Fax: 609-945-6080
www.princetonnj.gov

FIRE SAFETY PERMIT

LOCATION INFORMATION:

Name: Say Cheez
Street Address: 183D Nassau Street
Municipality: Princeton
County: Mercer
State: NJ
Zip Code: 08542
Local ID #: 003910 - 000113
State ID #:

PERMIT INFORMATION:

Permit Number: 18081544284
Permit Type: Type 1 - Cooking suppression system
Permit Fee: \$100.00
Date Issued: 8/15/2018
Date Expires: 8/14/2019

Approval is contingent on adherence to the following conditions. Failure to comply with the fire code requirements or any conditions set forth below is cause for revocation of this permit.

N.J.A.C. 5:70-2.7(a)3.xii. Any permanent cooking operation that requires a suppression system in accordance with N.J.A.C. 5:70-4.7(g) and is not defined as a life hazard use in accordance with N.J.A.C. 5:70-2.4.

Commercial kitchen hoods shall comply with N.J.A.C. 5:70-3 608. Wet chemical suppression systems shall comply with N.J.A.C. 5:70-3 904.5 (copies of both available upon request).

Joseph Novak, Fire Official

8/15/2018

DATE OF APPROVAL

This permit must be posted in a conspicuous location at the above premise.

This permit is issued in accordance with N.J.A.C. 5:70-2.7.